

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

November 14, 2017

Brandon M Gorte, P E
Midwest Environmental Consulting Serv.
4 Bonnie Lane
Yorkville, IL 60560

Workorder: 1711261

TEL: (630) 553-3989

FAX:

RE: MEC Project 17-10-834-IH Berger-Vandenberg Elementary School Drinking
Water Lead Analysis

Dear Brandon M Gorte, P E:

Suburban Laboratories, Inc. received 28 sample(s) on 11/3/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Pat Rodriguez
Project Manager
708-544-3260 ext 214
pat@suburbanlabs.com



SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Midwest Environmental Consulting Serv.

Report Date: November 14, 2017

Project Name: MEC Project 17-10-834-IH Berger-Vandeberg Elementar

Workorder: 1711261

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711261-001A	BV-N1-DFB-1~First Floor North Drinking Fountain #2~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-002A	BV-N1-DFB-2~First Floor North Drinking Fountain #2~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-003A	BV-N1-DFD-1~First Floor North Drinking Fountain #4~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-004A	BV-N1-DFD-2~First Floor North Drinking Fountain #4~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-005A	BV-N1-DFE-1~First Floor North Drinking Fountain #5~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-006A	BV-N1-DFE-2~First Floor North Drinking Fountain #5~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-007A	BV-LNG-S-1~Teachers Lounge Sink~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-008A	BV-LNG-S-2~Teachers Lounge Sink~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-009A	BV-NO-S-1~Nurse's Office Sink~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-010A	BV-NO-S-2~Nurse's Office Sink~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-011A	BV-KIT-S-1~Kitchen Sink~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-012A	BV-KIT-S-2~Kitchen Sink~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-013A	BV-S1-DFA-1~First Floor South Drinking Fountain #1~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-014A	BV-S1-DFA-2~First Floor South Drinking Fountain #1~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-015A	BV-S1-DFB-1~First Floor South Drinking Fountain #2~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-016A	BV-S1-DFB-2~First Floor South Drinking Fountain #2~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-017A	BV-S1-DFC-1~First Floor South Drinking Fountain #3~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-018A	BV-S1-DFC-2~First Floor South Drinking Fountain #3~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Midwest Environmental Consulting Serv.

Report Date: November 14, 2017

Project Name: MEC Project 17-10-834-IH Berger-Vandeberg Elementar

Workorder: 1711261

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711261-019A	BV-N2-DFA-1~Second Floor North Drinking Fountain #1~First Draw	2.92	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-020A	BV-N2-DFA-2~Second Floor North Drinking Fountain #1~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-021A	BV-N2-DFC-1~Second Floor North Drinking Fountain #3~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-022A	BV-N2-DFC-2~Second Floor North Drinking Fountain #3~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-023A	BV-N2-DFD-1~Second Floor North Drinking Fountain #4~First Draw	3.11	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-024A	BV-N2-DFD-2~Second Floor North Drinking Fountain #4~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-025A	BV-S2-DFB-1~Second Floor South Drinking Fountain #1~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-026A	BV-S2-DFB-2~Second Floor South Drinking Fountain #1~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-027A	BV-S2-DFA-1~Second Floor South Drinking Fountain #2~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711261-028A	BV-S2-DFA-2~Second Floor South Drinking Fountain #2~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017

1711261-001A-28A

FIELD DATA FORM

School/Facility Name
 Berger-Vandenberg Elementary School
 ISBE ID: (ex:01-001-0001-01-00001)
 07-016-1490-02-2006

Address
 14833 Avalon Avenue
 Dolton, IL 60419

Sample Collector Name(s)
 Brandon Gorte

MMDYYYYY

HH24MM

Water system last used Date:

11022017

Time:

16:00

All samples must be collected in unpreserved 250 mL plastic bottles

	Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDYYYYY	Collection Time HH24MM	Fixture Type	Sample Type	Sample Vol.	Notes
1	0001	Main Building	BV-NL-DEF-1	1ST FLOOR NORTH	11032017	650	DF	First Draw	250	
2	0001	Main Building	BV-NL-DEF-2	DF #2	11032017	651		Flush	250	
3	0001	Main Building	BV-NL-DEF-1	#4	11032017	654		First Draw	250	
4	0001	Main Building	BV-NL-DEF-2	↓	11032017	655		Flush	250	
5	0001	Main Building	BV-NL-DEF-1	#5	11032017	654		First Draw	250	
6	0001	Main Building	BV-NL-DEF-2	↓	11032017	655		Flush	250	
7	0001	Main Building	BV-NL-DEF-1	↓	11032017	654		First Draw	250	
8	0001	Main Building	BV-NL-DEF-2	↓	11032017	655		Flush	250	
9	0001	Main Building	BV-LHC-S-1	TEACHERS	11032017	658	S	First Draw	250	
10	0001	Main Building	BV-LHC-S-2	LOUNGE SINK	11032017	659		Flush	250	
11	0001	Main Building	BV-NO-S-1	NURSE'S OFFICE	11032017	659		First Draw	250	
12	0001	Main Building	BV-NO-S-2	SINK	11032017	700		Flush	250	
13	0001	Main Building	BV-KIT-S-1	KITCHEN	11032017	703		First Draw	250	
14	0001	Main Building	BV-KIT-S-2	SINK	11032017	704		Flush	250	
15	0001	Main Building	BV-S1-DEA-1	1ST FLOOR	11032017	708	DF	First Draw	250	
16	0001	Main Building	BV-S1-DEA-2	SOUTH DF #1	11032017	709		Flush	250	
17	0001	Main Building	BV-S1-DEF-1	#2	11032017	707		First Draw	250	
18	0001	Main Building	BV-S1-DEF-2	↓	11032017	708		Flush	250	
19	0001	Main Building	BV-S2-DEF-1	#3	11032017	711		First Draw	250	
20	0001	Main Building	BV-S1-DEF-2	↓	11032017	712		Flush	250	
21	0001	Main Building	BV-N2-DEA-1	2ND FLOOR	11032017	716		First Draw	250	
22	0001	Main Building	BV-N2-DEA-2	NORTH DF #1	11032017	717		Flush	250	
23	0001	Main Building	BV-N2-DEF-1	#3	11032017	717		First Draw	250	
24	0001	Main Building	BV-N2-DEF-2	↓	11032017	716		Flush	250	
25	0001	Main Building	BV-N2-DEF-1	#4	11032017	720		First Draw	250	
26	0001	Main Building	BV-N2-DEF-2	↓	11032017	721		Flush	250	
27	0001	Main Building	BV-S2-DEA-1	2ND FLOOR	11032017	724		First Draw	250	
28	0001	Main Building	BV-S2-DEA-2	SOUTH DF #1	11032017	725		Flush	250	
29	0001	Main Building	BV-S2-DEF-1	#2	11032017	724		First Draw	250	
30	0001	Main Building	BV-S2-DEF-2	↓	11032017	725		Flush	250	
31	0001	Main Building	BV-____-1		11032017			First Draw	250	
32	0001	Main Building	BV-____-2		11032017			Flush	250	
33	0001	Main Building	BV-____-1		11032017			First Draw	250	
34	0001	Main Building	BV-____-2		11032017			Flush	250	
35	0001	Main Building	BV-____-1		11032017			First Draw	250	
36	0001	Main Building	BV-____-2		11032017			Flush	250	
37	0001	Main Building	BV-____-1		11032017			First Draw	250	
38	0001	Main Building	BV-____-2		11032017			Flush	250	
39	0001	Main Building	BV-____-1		11032017			First Draw	250	
40	0001	Main Building	BV-____-2		11032017			Flush	250	

See Client 11/3/17 10:25a