

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

November 10, 2017

Brandon M Gorte, P E  
Midwest Environmental Consulting Serv.  
4 Bonnie Lane  
Yorkville, IL 60560

**Workorder: 1711208**

TEL: (630) 553-3989

FAX:

RE: MEC Project 17-10-834-IH Carol Mosley Braun School Drinking Water  
Lead Analysis

Dear Brandon M Gorte, P E:

Suburban Laboratories, Inc. received 14 sample(s) on 11/2/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Pat Rodriguez  
Project Manager  
708-544-3260 ext 214  
pat@suburbanlabs.com



# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Client ID:** Midwest Environmental Consulting Serv.

**Report Date:** November 10, 2017

**Project Name:** MEC Project 17-10-834-IH Carol Mosley Braun School

**Workorder:** 1711208

**Analyte:** Lead

**Method:** EPA 200.8

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711208-001A	CB-W-DFA-1~West Drinking Fountain #1~First Draw	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-002A	CB-W-DFA-2~West Drinking Fountain #1~Flush	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-003A	CB-W-DFB-1~West Drinking Fountain #2~First Draw	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-004A	CB-W-DFB-2~West Drinking Fountain #2~Flush	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-005A	CB-E-DFA-1~East Drinking Fountain #1~First Draw	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-006A	CB-E-DFA-2~East Drinking Fountain #1~Flush	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-007A	CB-E-DFB-1~East Drinking Fountain #2~First Draw	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-008A	CB-E-DFB-2~East Drinking Fountain #2~Flush	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-009A	CB-CAFE-S-1~Cafeteria Sink~First Draw	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-010A	CB-CAFE-S-2~Cafeteria Sink~Flush	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-011A	CB-NO-S-1~Nurse's Office Sink~First Draw	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-012A	CB-NO-S-2~Nurse's Office Sink~Flush	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-013A	CB-LNG-S-1~Teachers Lounge Sink~First Draw	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017
1711208-014A	CB-LNG-S-2~Teachers Lounge Sink~Flush	ND	2.00	µg/L	11/01/2017 16:00	11/2/2017	11/8/2017

FIELD DATA FORM

School/Facility Name
Carol Mosley Braun School
ISBE ID: (ex:01-001-0001-01-00001)
07-016-1490-02-2009

Address
1655 153rd Street
Calumet City, IL 60409

Sample Collector Name(s)
Brandon Gorte

MMDDYYYY

HH24MM

All samples must be collected in unpreserved 250 mL plastic bottles

Water system last used Date:

11012017

Time:

16:00

	Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDDYYYY	Collection Time HH24MM	Fixture Type	Sample Type	Sample Vol.	Notes
1	Do Not Use									
2	Do Not Use									
3	0001	Main Building	CB-W-DEA-1	WEST DF #1	11022017	735	DF	First Draw	250	
4	0001	Main Building	CB-W-DEA-2	"	11022017	736		Flush	250	
5	0001	Main Building	CB-W-DEB-1	#2	11022017	738		First Draw	250	
6	0001	Main Building	CB-W-DEB-2	"	11022017	739		Flush	250	
7	0001	Main Building	CB-E-DEA-1	EAST DF #1	11022017	740		First Draw	250	
8	0001	Main Building	CB-E-DEA-2	"	11022017	741		Flush	250	
9	0001	Main Building	CB-E-DEB-1	#2	11022017	743		First Draw	250	
10	0001	Main Building	CB-E-DEB-2	"	11022017	744	∇	Flush	250	
11	0001	Main Building	CB-CAF-S-1	CAFETERIA	11022017	746	KS	First Draw	250	
12	0001	Main Building	CB-CAF-S-2	SINK	11022017	747	∇	Flush	250	
13	0001	Main Building	CB-NO-S-1	NURSE'S OFFICE	11022017	750	S	First Draw	250	
14	0001	Main Building	CB-NO-S-2	SINK	11022017	751		Flush	250	
15	0001	Main Building	CB-LNG-S-1	TEACHERS	11022017	752		First Draw	250	
16	0001	Main Building	CB-LNG-S-2	LUNCH SINK	11022017	753	∇	Flush	250	
17	0001	Main Building	CB-____-1		11022017			First Draw	250	
18	0001	Main Building	CB-____-2		11022017			Flush	250	
19	0001	Main Building	CB-____-1		11022017			First Draw	250	
20	0001	Main Building	CB-____-2		11022017			Flush	250	

Re Client 11/2/17 11:10a