

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

November 14, 2017

Brandon M Gorte, P E  
Midwest Environmental Consulting Serv.  
4 Bonnie Lane  
Yorkville, IL 60560

**Workorder: 1711259**

TEL: (630) 553-3989

FAX:

RE: MEC Project 17-10-839-IH New Beginnings Learning Academy Drinking  
Water Lead Analysis

Dear Brandon M Gorte, P E:

Suburban Laboratories, Inc. received 18 sample(s) on 11/3/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Pat Rodriguez  
Project Manager  
708-544-3260 ext 214  
pat@suburbanlabs.com



# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Client ID:** Midwest Environmental Consulting Serv.

**Report Date:** November 14, 2017

**Project Name:** MEC Project 17-10-839-IH New Beginnings Learning Ac

**Workorder:** 1711259

**Analyte:** Lead

**Method:** EPA 200.8

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711259-001A	NB-GYM-DFA-1~Gym Drinking Fountain #1~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711259-002A	NB-GYM-DFA-2~Gym Drinking Fountain #1~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/3/2017	11/9/2017
1711259-003A	NB-GYM-DFB-1~Gym Drinking Fountain #2~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-004A	NB-GYM-DFB-2~Gym Drinking Fountain #2~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-005A	NB-KIT-S-1~Kitchen Sink~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-006A	NB-KIT-S-2~Kitchen Sink~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-007A	NB-NO-S-1~Nurse's Office Sink~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-008A	NB-NO-S-2~Nurse's Office Sink~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-009A	NB-LNG-S-1~Teachers Lounge Sink~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-010A	NB-LNG-S-2~Teachers Lounge Sink~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-011A	NB-1-DFA-1~First Floor Drinking Fountain #1~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-012A	NB-1-DFA-2~First Floor Drinking Fountain #1~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-013A	NB-1-DFB-1~First Floor Drinking Fountain #2~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-014A	NB-1-DFB-2~First Floor Drinking Fountain #2~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-015A	NB-2-DFA-1~Second Floor Drinking Fountain #1~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-016A	NB-2-DFA-2~Second Floor Drinking Fountain #1~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-017A	NB-2-DFB-1~Second Floor Drinking Fountain #2~First Draw	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017
1711259-018A	NB-2-DFB-2~Second Floor Drinking Fountain #2~Flush	ND	2.00	µg/L	11/02/2017 16:00	11/2/2017	11/9/2017

1711259-001A-18A

FIELD DATA FORM

School/Facility Name
New Beginnings Learning Academy
ISBE ID: (ex:01-001-0001-01-00001)
07-016-1490-02-2010

Address
15703 Clyde Avenue
South Holland, IL 60473

Sample Collector Name(s)
Brandon Gorte

MMDDYYYY

HH24MM

All samples must be collected in unpreserved 250 mL plastic bottles

Water system last used Date:

11022017

Time:

16:00

	Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDDYYYY	Collection Time HH24MM	Fixture Type	Sample Type	Sample Vol.	Notes
1	Do Not Use									
2	Do Not Use									
3	0001	Main Building	NB-GYM-DEA-1	GYM DF #1	11032017	828	DF	First Draw	250	
4	0001	Main Building	NB-GYM-DEA-2	↓	11032017	829	↓	Flush	250	
5	0001	Main Building	NB-GYM-DFB-1	#2	11022017	830	↓	First Draw	250	
6	0001	Main Building	NB-GYM-DFB-2	↓	11022017	831	↓	Flush	250	
7	0001	Main Building	NB-KIT-S-1	KITCHEN	11022017	834	S	First Draw	250	
8	0001	Main Building	NB-KIT-S-2	SINK	11022017	835	↓	Flush	250	
9	0001	Main Building	NB-NO-S-1	NURSES	11022017	836	S	First Draw	250	
10	0001	Main Building	NB-NO-S-2	OFFICE SINK	11022017	837	↓	Flush	250	
11	0001	Main Building	NB-LNG-S-1	TEACHERS	11022017	842	S	First Draw	250	
12	0001	Main Building	NB-LNG-S-2	LUNGE SINK	11022017	843	↓	Flush	250	
13	0001	Main Building	NB-1-DEA-1	1ST FLWR DF	11022017	842	DF	First Draw	250	
14	0001	Main Building	NB-1-DEA-2	#1	11022017	843	↓	Flush	250	
15	0001	Main Building	NB-1-DFB-1	#2	11022017	844	↓	First Draw	250	
16	0001	Main Building	NB-1-DFB-2	↓	11022017	845	↓	Flush	250	
17	0001	Main Building	NB-2-DEA-1	2 <sup>ND</sup> FLWR DF	11022017	849	↓	First Draw	250	
18	0001	Main Building	NB-2-DEA-2	#1	11022017	850	↓	Flush	250	
19	0001	Main Building	NB-2-DFB-1	#2	11022017	849	↓	First Draw	250	
20	0001	Main Building	NB-2-DFB-2	↓	11022017	850	↓	Flush	250	

lec Client to  
 11/3/17 10:25a lec 11/3/17